



38' CONCRETE PAVEMENT SECTION TYPICAL CROSS SECTION

NTS

NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS
AT 15' INTERVALS FOR CONCRETE PAVEMENT.
- * 2. LIME SHALL BE APPLIED AT 6% BY WEIGHT
MINIMUM QUANTITY IS 36#/SY. IN SOME
AREAS A GREATER QUANTITY (OR A LIME
SERIES TEST) MAY BE REQUIRED AT THE
CITY'S DISCRETION.
- ** 3. CEMENT SHALL BE APPLIED AT 5% BY
WEIGHT. MINIMUM QUANTITY IS 36#/SY.

REVISIONS	REVISIONS
	Revised 11/16/99 (Bar Size & Concrete Layer Thickness)
CITY OF ARLINGTON, TEXAS	
PROJECT NUMBER	
PROJECT NAME	
(PROJECT LIMITS)	
DATE:	SCALE: SHEET OF
DESIGNED BY:	DRAWN BY: CHECKED BY: